

---

# DECLARATION of CONFORMITY

---

1. The Product Family

## Fire Alarm Bells (LPCB Approved)

41-100	ZT-BELL/6	24V 6" Fire Alarm Bell, Shallow Base, Red EN54-3
41-101	ZT-BELL/6/D	24V 6" Fire Alarm Bell, Deep Base, Red EN54-3
41-102	ZT-BELL/6/WP	24V 6" Fire Alarm Bell, Weatherproof, Red EN54-3

2. These products are manufactured by Zeta Alarms Limited, at Detection House, 72-78 Morfa Road, Swansea, SA1 2EN. U.K.

3. This declaration is issued under the sole responsibility of the manufacturer.

4. The object of the declaration described in point 1 is in conformity with the relevant Union harmonisation legislation

2014/30/EU	EMC Directive
2011/65/EU	Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)
2014/35/EU	Electrical equipment designed for use within certain voltage limits (LVD)

5. References to the relevant harmonised standards used, or references to the specifications in relation to which conformity is declared:

BS EN 62368-1:2020 +A11:2020	Audio/video, information and communication technology equipment - Safety requirements
BS EN 61000-6-3:2007 +A1:2011	Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments. Emissions, Class B.
BS EN 50130-4:2011 +A1:2014	Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

Signed for and on behalf of Zeta Alarms Limited

Name: **N.R. P. Jones** Position: **Technical Manager**  
Place of issue: **Swansea**  
Date of issue: **24<sup>th</sup> July 2024**

Signature:

A handwritten signature in blue ink, appearing to be "N.R. P. Jones", written over a light blue horizontal line.