



MANUFACTURERS OF FIRE ALARM EQUIPMENT

---

## DECLARATION of CONFORMITY

---

The manufacturers (Zeta Alarms Ltd, 72-78 Morfa Road, Swansea, SA1 2EN) declares that

### Premier EX Pro Output Expansion Relay PCB

37-097	EX-OER3	Premier Ex Pro Output Expansion – 3 relay PCB
37-099	EX-OER8	Premier Ex Pro Output Expansion – 8 relay PCB

Complies to the following standards:

Emission: EN61000-6-3 :2007

Immunity: EN50130-4 :2003

European Standard:

---

and thereby, complies with the ESSENTIAL REQUISITES of DIRECTIVE 2004/108/EC



For and on behalf of  
Zeta Alarms Ltd  
D. Zachariah  
QUALITY ASSURANCE  
MANAGER

Date: 11.09.2017