



MANUFACTURERS OF FIRE ALARM EQUIPMENT

DECLARATION of CONFORMITY

The manufacturers (Zeta Alarms Ltd, 72-78 Morfa Road, Swansea, SA1 2EN) declares that

Zeta Mains Operated Detectors Interlinkable up to 38 Units

| | | |
|--------|-------------|-------------------------------------------------------------|
| 47-038 | ZT-MAINS-5 | Zeta Mains photoelectric smoke alarm with 9V battery backup |
| 47-039 | ZT-MAINS-H5 | Zeta Mains Heat Detector with 9V battery backup |

Complies to the following standards:

Emission: EN61000-6-3 :2007

Immunity: EN50130-4 :2003

European Standard:

and thereby, complies with the ESSENTIAL REQUISITES of DIRECTIVE 2004/108/EC



For and on behalf of
Zeta Alarms Ltd
D. Zachariah
QUALITY ASSURANCE
MANAGER

Date: 11.09.2017