

BRE Global

Notified Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0) 333 321 8811 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Certificate of constancy of performance 0832-CPR-F2045

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MKII-AXT/R Zeta Addressable Xtratone Type A Indoor Sounder (Red) (For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Zeta Alarms Limited Detection House 72-78 Morfa Road Swansea SA1 2EN United Kingdom and produced in the manufacturing plant(s):

Zeta Alarms Limted Detection House 72-78 Morfa Road Swansea SA1 2EN United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 January 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P. Malligar

P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue:16 January 2018Date of Issue:16 January 2018Issue number01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.



BRE Global Limited Bucknalls Lane,

Garston, Watford, Hertfordshire, UK, WD25 9XX Notified Body No. 0832 Telephone: +44 (0) 333 321 8811 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> web: <u>www.breglobal.com</u>

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2045

MKII-AXT/R Zeta Addressable Xtratone Type A Indoor Sounder (Red)

Note:

1. Meets the requirements of EN54-3 at the following tones:

- Tone 0: 800Hz and 970Hz, 500ms each
- Tone 8: 500Hz 1200Hz, 3.5s sweep, 0.5s silence, repeat Dutch Slow Whoop

Variants:

MKII-AXT/W – Zeta Addressable Xtratone Type A Indoor Sounder (White)

P. Walligan

P Halligan, Certification Manager, On behalf of BRE Global Limited Date of First Issue:16 January 2018Date of Issue:16 January 2018Issue number:01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.