Issue date: 2017-09-29



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FEAHE2000 HEAT Analogue addressable Heat detector with output for LED

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Zeta Alarms Limited 72-78 Morfa Road, Haford, Swansea, SA1 2EN, United Kingdom

and produced in the manufacturing plant:

CPA10001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN54-5:2000/A1:2002 : Fire detection and fire alarm systems –

Part 5: Heat detectors – Point detectors

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2017-09-29

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2017-03-10)

This certificate was first issued 2014-08-01.

Klaus Mühlbach Responsible for evaluation Merete Poulsen

Responsible for certification decision

Prod. Reg. Nr. 7023

Issue date: 2017-09-29



Annex 1

EXTENT

Type:

Fyreye detector type FEAHF2000 HEAT

Analogue addressable Heat detector with output for LED

Must be installed in Fyreye Common Base Part no. 45681-200GLT.

Performance

Essential characteristics	Clauses in EN 54-5:2000	Performance
Nominal activation	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1 ^a , 6.2 ^b	Pass
conditions/Sensitivity, Response		
delay (response time) and		
Performance under fire conditions		
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability	5.9, 5.10	Pass
and response delay; temperature		
resistance		
Durability of operational	5.14, 5.17	Pass
reliability; vibration resistance		
Durability of operational	5.11, 5.12	Pass
reliability; humidity resistance		
Durability of operational	5.13	Pass
reliability; corrosion resistance		
Durability of operational	5.18	Pass
reliability; electrical stability		

Issue date: 2017-09-29



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DELTA	DANAK-199813, Rev. 1	2007-01-11
DELTA	DANAK-199748	2005-04-21

Issue date: 2017-09-29



Annex 3

TECHNICAL BASIS

File Number	Title	Date
WizMart	RD06-GLT00, Version 1.1	2006-11-14
GLT-FEA2000 document	VOISION III	
- For DBI Certificate Application		