Issue date: 2018-01-11



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

ZT-CP3

Manual Call Point for outdoor use, IP67

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Zeta Alarms Limited 72-78 Morfa Road, Haford, Swansea, SA1 2EN, United Kingdom

and produced in the manufacturing plant:

CPA10012

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001 : Fire Detection and fire alarm systems –

EN 54-11:2001/A1:2005 Part 11:Manual Call Points.

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2018-01-11.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2014-04-24)

This certificate was first issued 2014-08-01.

Merete Poulsen Responsible for evaluation Klaus Mühlbach Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Prod. Reg. Nr. 7023

Issue date: 2018-01-11



Annex 1

EXTENT

Type:

ZT-CP3

Manual Call Point for outdoor use, IP67

Performance

Essential characteristics	Clauses in EN 54-11:2001/ A1:2005	Performance
Nominal activation conditions/Sensitivity and	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	Pass
Performance under fire conditions		
Operational reliability	4.4 to 4.11	Pass
Durability of operational reliability temperature resistance	5.7, 5.19	Pass
Durability of operational reliability; vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability; humidity resistance	5.10, 5.12, 5.19	Pass
Durability of operational reliability; corrosion resistance	5.11, 513	Pass
Durability of operational reliability; electrical stability	5.6, 5.18	Pass

Issue date: 2018-01-11



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DELTA	DANAK-1910744 Rev. B Project no.: A530602	2010-10-01

Issue date: 2018-01-11



Annex 3

TECHNICAL BASIS

File Number	Title
Drawing Register	Drawing Register 0845-CPR-232_1688