



The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

15LHK0084-02

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC 17067:2013, we certify that the product(s)

## Input / Output Modules Incorporating Short Circuit Isolators

are in conformity with the following standard(s):  
**EN54-17:2005+AC:2007, EN54-18:2005+AC:2007**

Report Number(s):  
101509912LHD-001

### Zeta Alarms Limited

Detection House, 72-78 Morfa Road, Swansea, SA1 2EN, United Kingdom

and are authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product(s)

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

<b>Limitations:</b>	<b>Certification Body:</b> ITCL
	<b>LSS Reference:</b> LSS 0330
	<b>Issued Date:</b> 13 <sup>th</sup> November 2017

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Nick Jones





The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate 15LHK0084-02

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

## ANNEX No. 1

Brand and Type/Model	Description	Factory Code
ZAI-MI	Addressable Input Module with Short Circuit Isolator	GLTEXPUK.01
ZAIO-MI	Addressable Input / Output Module with Short Circuit Isolator	GLTEXPUK.01
ZASC-MI	Addressable Sounder Control Module with Short Circuit Isolator	GLTEXPUK.01
ZAZM-MI	Addressable Zone Monitor Module with Short Circuit Isolator	GLTEXPUK.01

## ANNEX No. 2

### Conditions of use: -

Suitable for indoor applications.

Models ZAI-MI, ZAIO-MI, ZASC-MI and ZAZM-MI are designed to be used with suitable / compatible control and indicating equipment (CIE).

Model ZASC-MI requires a connected 24 VDC power supply for operation\*.

\* If powering EN54 devices, an EN54-4 compliant power supply (PSE) is required.

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.